

ULR No.:-	--	Group/ Discipline:	Environmental/Electrical
Test Report No.	STC/TEST/N20220207003		Date of Issue: 14/02/2022

Name & Address of Customer:	DEE FIVE SHRINK INSULATIONS PVT LTD. PLOT NO. 165, HSIIDC, FOOTWEAR PARK, BAHADURGARH-124507, HARYANA		
Name & Address of Manufacturer (If required):	--		
Customer Ref. & Date:	Nil	W.O. No: N20220207003	
Date of Sample Receipt: 07/02/2022	Start of Test Date: 07/02/2022	End of Test Date: 10/02/2022	

**PART A - PARTICULARS OF THE SAMPLE SUBMITTED**



Sample description	Sleeve
Grade/ variety/ type/ class/ size etc.	Thickness – 0.15 mm
Declared values, if any	--
Code no., BIS seal and IO's sign. if any	--
Batch no., date of manufacture and Brand Name	--
Name & Address of Manufacturer (If required)	DEE FIVE SHRINK INSULATIONS PVT LTD. PLOT NO. 165, HSIIDC, FOOTWEAR PARK, BAHADURGARH-124507, HARYANA
Serial No.	--
Quantity	1 No.
Condition of the sample	OK
Reference specification (s)	---
Environmental conditions	Temperature (20±5)°C & Relative Humidity(45-75)%

**PART-B: SUPPLEMENTARY INFORMATION**

1. If an Item is tested, acknowledging deviations from specified conditions as requested by customers, the results may be affected due to this deviation.
2. Details of the drawings, graphs, tables, sketches or photographs as referred in the test report, if any:

**Notes:**

1. This report is not to be reproduced except in full/partial without approval of the laboratory in writing.
2. This report refers only to the particular sample detailed above.
3. The results reported in this Test report are valid at the time of and under the stipulated conditions of measurement.

Tested by	Approved by
	
(Ritesh Kumar/Testing Engineer)	(Shaktiman sangam/QM/TM)

Format No. - STCLAB/F/EL/06



# STANDARD TESTING & COMPLIANCE (STC LAB)

Page No.: 2 of 3


ULR No.:-	--	Group/ Discipline:	Environmental/Electrical
Test Report No.	STC/TEST/N20220207003		Date of Issue: 14/02/2022

Cl. No.	Test / Requirement	Test result/ observation	Verdict
1.	High Voltage Test	Sample with stands at 11 kV at for 1 minutes	Pass
2.	Thickness	Thickness = 0.15mm	Complies






ULR No.:-	--	Group/ Discipline:	Environmental/Electrical
Test Report No.	STC/TEST/N20220207003	Date of Issue:	14/02/2022

**Photograph of Sample:**



**PART D:-**

**REMARKS:**

Tested by	Approved by
	
(Ritesh Kumar/Testing Engineer)	 (Shaktiman sangam/QM/TM)

\*\*\*\*\* END OF TEST REPORT \*\*\*\*\*